

VOC Content Test Certificate

Friday 31st March 2023

Supplier: Selleys Pty Ltd (1 Gow Street, PADSTOW, NSW, 2211, Australia)

Sample Description: Selleys Liquid Nails Exterior Grip

Date Tested: March 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p>	<p align="center">Selleys Liquid Nails Exterior Grip</p>
<p align="center">General Purpose Adhesives and Sealants Limit: 50 grams per litre</p>	<p align="center">33 grams per litre as VOC content per material</p>
<p align="center">Meets GBCA VOC Content Requirement</p>	<p align="center">Yes</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue date: 31/03/2023

Expiry date: 31/03/2028

P23030096